



# Rack Fire Hoses

## NEW CODE REQUIREMENT

### NEW CODE REQUIREMENTS:

- Monthly inspection of Fire Hoses.
- Annual testing of Fire Hose Nozzles.
- Annual testing of Fire Hose Storage Devices.
- Annual Main Drain Test.
- Fire Hoses must be Hydro-Static tested every 5 years.
- Pressure Reducing Valves tested every 5 years.

**TFP performs a free site survey of your property an order to meet FDNY & NFPA 25 code requirements.**



Fire Hose Installations

### CONTACT US

Sales & Customer Service  
9:00 a.m. - 5:00 p.m. EST  
Monday - Friday

Phone  
[718-951-7200](tel:718-951-7200)

Fax  
[718-377-6600](tel:718-377-6600)

Email  
[sales@tfp1.com](mailto:sales@tfp1.com)

Website  
[www.tfp1.com](http://www.tfp1.com)



Standpipe Control Valve